

Temperature Settings for HVAC Equipment

In order to comply with federal, state and District policies, space temperatures will be set in accordance with the following guidelines:

COOLING:

- *76° Fahrenheit, (+/-) 2 degrees, for school areas, including classrooms, media centers, and other non-instructional spaces.*
- *Gymnasiums may also be cooled to 76° Fahrenheit, (+/-) 2 degrees, during official school activities or school-approved events.*
- *During periods of high humidity, acceptable temperature settings and times of use will be determined by both the Energy Coordinator and the Environmental Specialist.*

HEATING:

- *68° Fahrenheit, (+/-) 2 degrees, for all conditioned rooms.*
- 76° F cool*
68° F heat

EXHAUST:

- *Set temperature indicator control to 85° Fahrenheit for all exhaust fans located in electrical rooms*

HUMIDITY:

- *Libraries and Media Centers are to be kept below sixty (60) percent relative humidity.*

NOTE: *All guidelines listed on the document, State Requirements for Educational Facilities 2007 (SREF), which was approved on 12/11/07, and became effective 02/12/08, shall be observed.*

